

TC 331 tank 1-year inspection checklist

Form Number:NEE-FRM-010	Revision: 0
Date: Tank Owner: Address:	
Serial #: Tank Spec: Shell Material: Comp. Sizes: Original Test Date: M.A.W.P.: Tests Performed: V K Hose Test	_ MFG Date:
Tank and attachments must be clean prior to inspection	
Working from Heights policies are in effect	
External Visual "V"	
-Inspect data plate [12.2] (legible, permanently affixed, has all information required in 12.2) PassFailN/A	
-Inspect tank inspection decals [12.2] (verify what tests an	re required, 1 year or 5 year) Pass Fail N/A
-Inspect tank bulk heads and shell [12.2] (Check for corrosion, dents, distortions, defects in welds, leakage, damage indicating weakness in the tank that could render it unsafe for transport, voids on bottom of tank are not capped and show no signs of leakage.) Pass Fail N/A	
-Inspect fenders and attachments [12.2] (Ladder/drop hos mounting)	se compartments latch, cracks, damage to fenders or Pass Fail N/A
-Inspect bumper / rear end protection [12.2] (Securely mounted, welds, damage, correct dimensions, distance between widest part of rear of vehicle and outward edge of bumper does not exceed 18" distance between bottom of bumper and ground is less than 30" when empty,) PassFailN/A	
-Inspect rear tank sills/frame [12.2] (damage, welds)	Pass Fail N/A
-Inspect placards (correct product, legible, all 4 present)	Pass Fail N/A
-Inspect tank mounts [12.2] (unable to loosen with wrench [wood/rubber etc.])	n, welds on brackets, condition of sill fil material Pass Fail N/A
 -Inspect underslung boxes [12.2] (hydraulic leaks, fitting/tvalves/air switches work correctly, grasshopper springs) -Inspect slam latches/door safety latches [12.2] (all latch -Inspect cabinet doors (damage, seal properly when closed -Inspect all air switches (make sure all switches work) -Inspect emergency switches (verify operation of all) -Inspect underneath tank [12.2] (dents, corrosion, leaks, Is voids are not capped, pipes for dents/rubbing, hydraulics, e Outlet valve) 	PassFailN/A correctly) PassFailN/A PassFailN/A PassFail_N/A PassFail_N/A PassFail_N/A PassFail_N/A
-Inspect on top of tank [12.2] (dents, corrosion, fall protect wearing tank, obvious signs of leakage,	tion functions (if equipped), anti-slip grating insecure or Pass Fail N/A
Leakage Test "K"	Test Pressure
Dedicated service, the test pressure shall be the maximum normal operating pressure of the tank, MC 330, MC 331 or TC 331 in LPG or NH3 service shall be tested at no less than 60 PSI. - Pressure test compartment and all associated, - Spray with soapy water all welds pipe connections, meter and pump equipment for signs and observe for signs of leaks.	
TANK [12.5]	NG [12.5] Pass Fail N/A
PUMP [12.5]	ER [12.5] Pass Fail N/A



TC 331 tank 1-year inspection checklist

Form Number: NEE-FRM-010 Revision: 0 **Emergency Discharge Control [12.2]** Pass___ Fail___ N/A___ Page 2 of 2 -TC 331 tanks that transport liquefied compressed gas (LPG) are required to have Emergency discharge controls, except designed to transport Class 2.2, non-flammable and non-toxic gases. -Tanks that are 13,250L or less, equipped for metered Service, need an off-truck emergency shutdown system. -Tanks that are 13,250L or more, equipped for metered service, will need either a monitoring feature or a passive emergency shutdown system in addition to an off-truck emergency shut down system. -The system will be tested at the time of inspection, -With product running at normal flow rate throughout the metering system, activate the off-truck Emergency shutdown system (normally this would be a BASE Engineering product). Observe the meter to determine how long it takes to stop the product flow. The meter should stop the flow and close the ISC within 30 seconds or sooner. No meter creep after 5 seconds. -The same process for testing the Emergency Discharge Controls shall be used on both ON and OFF truck applications. -The emergency shut down system shall function reliably at a distance of 46 m (150ft) and -When the Emergency shutdown has been activated, the ISC can't be reactivated remotely. -Indicate results on Test and Inspection Report (Form No: NEE-FR-L-007). -For non-metered tanks, all ISC valves shall be open. Each emergency discharge control remote actuator (on-truck and off truck) shall be operated to ensure each ISC valve indicator has moved to the closed position. Once all ISC valves are closed, all of the material in the downstream piping shall be evacuated, and the piping shall be returned to atmospheric temperature and pressure. The outlet shall then be monitored for 30 seconds to ensure that there is no detectable leakage. Hose Test [12.2 & 12.9] **-Perform visual inspection of all hoses** (look for kinks, exposed re-enforcement, damaged ends, gaskets) Pass___ Fail___ N/A___ **-Pressure test all hoses** (hold pressure for 5 minutes) Pass___ Fail___ N/A___ Hose I.D. Test Press. (Test/MAWP) Test Medium : _____ Fail Items **Failure Corrected** Y N ONLY AFTER SUCCUSSFEUL TEST WILL MARKINGS BE APPLIED Has inspection sticker been applied to tank? (Sticker must be affixed Driver-side front of the barrel and clearly visible) Has B620 test and inspection report been filled out? ** Take picture of Data Plate and attach to NEEI copy of Inspection Report**